



## BACnet Protocol Implementation Conformance Statement

### Products

Product	Model Number	Protocol Revision	Software Version	Firmware Version
BACnet Device Simulator	SE-SIM	135-2020 (22)	6.0.24	6.0.24

Date Tested: 2 February 2023

### Vendor Information

11 Buccaneer Avenue  
Lammermoor, Queensland  
Australia

### Product Description

The SCADA Engine BACnet Device Simulator is used to simulate 1 or more BACnet Devices.

### BACnet Standardized Device Profile

Product	Device Profile	Tested
SE-SIM	BACnet Application Specific Controller (B-ASC)	



**Supported BIBBs**

Product	Supported BIBBs	BIBB Name	
SE-SIM	DS-RP-A	Data Sharing-ReadProperty-A	
	DS-RP-B	Data Sharing-ReadProperty-B	
	DS-RPM-A	Data Sharing-ReadPropertyMultiple-A	
	DS-RPM-B	Data Sharing-ReadPropertyMultiple-B	
	DS-WP-A	Data Sharing-WriteProperty-A	
	DS-WP-B	Data Sharing-WriteProperty-B	
	DS-WPM-A	Data Sharing-WritePropertyMultiple-A	
	DS-WPM-B	Data Sharing-WritePropertyMultiple-B	
	DS-COV-A	Data Sharing-COV-A	
	DS-COV-B	Data Sharing-COV-B	
	DS-COVP-A	Data Sharing-COVP-A	
	DS-COVP-B	Data Sharing-COVP-B	
	DS-COVU-A	Data Sharing-COV-Unsolicited-A	
	DS-COVU-B	Data Sharing-COV-Unsolicited-B	
	SCHEM-A	Scheduling-A	
	SCHEM-I-B	Scheduling-Internal-B	
	SCHEM-E-B	Scheduling-External-A	
	T-VMT-A	Trending-Viewing and Modifying Trends-A	
	T-VMT-I-B	Trending-Viewing and Modifying Trends-Internal-B	
	T-VMT-E-B	Trending-Viewing and Modifying Trends-External-B	
	T-ATR-A	Trending-Automated Trend Retrieval-A	
	T-ATR-B	Trending-Automated Trend Retrieval-B	
	NM-CE-A	Network Management-Connection Establishment-A	
	NM-CE-B	Network Management-Connection Establishment-B	
	AE-N-A	Alarm and Event-Notification-A	
	AE-N-I-B	Alarm and Event-Notification Internal-B	
	AE-N-E-B	Alarm and Event-Notification External-B	
	AE-ACK-A	Alarm and Event-ACK-A	
	AE-ACK-B	Alarm and Event-ACK-B	
	AE-ASUM-A	Alarm and Event-Alarm Summary-A	
	AE-ASUM-B	Alarm and Event-Alarm Summary-B	
	AE-ESUM-A	Alarm and Event-Enrollment Summary-A	
	AE-ESUM-B	Alarm and Event-Enrollment Summary-B	
	AE-INFO-A	Alarm and Event-Information-A	
AE-INFO-B	Alarm and Event-Information-B		
AE-LS-A	Alarm and Event-LifeSafety-A		
AE-LS-B	Alarm and Event-LifeSafety-B		



Product	Supported BIBBs	BIBB Name	
	DM-RD-A	Device Management-ReinitializeDevice-A	
	DM-RD-B	Device Management-ReinitializeDevice-B	
	DM-DDB-A	Device Management-Dynamic Device Binding-A	
	DM-DDB-B	Device Management-Dynamic Device Binding-B	
	DM-DOB-A	Device Management-Dynamic Object Binding-A	
	DM-DOB-B	Device Management-Dynamic Object Binding-B	
	DM-DCC-A	Device Management-DeviceCommunicationControl-A	
	DM-DCC-B	Device Management-DeviceCommunicationControl-B	
	DM-PT-A	Device Management-Private Transfer-A	
	DM-PT-B	Device Management-Private Transfer-B	
	DM-TM-A	Device Management-Text Message-A	
	DM-TM-B	Device Management-Text Message-B	
	DM-TS-A	Device Management-TimeSynchronization-A	
	DM-TS-B	Device Management-TimeSynchronization-B	
	DM-UTC-A	Device Management-UTCTimeSynchronization-A	
	DM-UTC-B	Device Management-UTCTimeSynchronization-B	
	DM-LM-A	Device Management-List Manipulation-A	
	DM-LM-B	Device Management-List Manipulation-B	
	DM-OCD-A	Device Management-Object Creation and Deletion-A	
	DM-OCD-B	Device Management- Object Creation and Deletion -B	



### Standard Object Types Supported

Product	Object Type	Creatable	Deletable	Tested
SE-SIM	Analog Input	Yes	Yes	
	Analog Output	Yes	Yes	
	Analog Value	Yes	Yes	
	Binary Input	Yes	Yes	
	Binary Output	Yes	Yes	
	Binary Value	Yes	Yes	
	Calendar	Yes	Yes	
	Device	No	No	
	Event Enrollment	Yes	Yes	
	File	Yes	Yes	
	Loop	Yes	Yes	
	Multi-state Value	Yes	Yes	
	Notification Class	Yes	Yes	
	Program	Yes	Yes	
	Schedule	Yes	Yes	
	Trend Log	Yes	Yes	
	LifeSafetyPoint	Yes	Yes	
	LifeSafetyZone	Yes	Yes	
Accumulator	Yes	Yes		
PulseConverter	Yes	Yes		

### Data Link Layer Options

Product	Data Link	Options	Tested
SE-SIM	BACnet/IP (Annex J)	Can communicate as a Direct BACnet/IP device. Can register as a Foreign BACnet/IP device.	

### Segmentation Capability

Product	Segmentation Type	Supported	Window Size (MS/TP product limited to 1)	Tested
SE-SIM	Able to transmit segmented messages	Yes	Configurable	
	Able to receive segmented messages	Yes	Configurable	



### Device Address Binding

Product	Static Binding Supported	Tested
SE-SIM	Yes	

### Networking Options

Product	Router Option	Options	Tested
SE-SIM			

### Character Sets

Product	Character Sets supported	
SE-SIM	ANSI X3.4	
	IBM Microsoft DBCS	
	ISO 8859-1	